

CIRLOCK

CIRLOCK – LOCKOUT / TAGOUT EQUIPMENT

Cable Lockout Device

MFL-2

Instructions

Warning: Always perform a De-Energization Test both before and after using this product. Always perform a Blocking Verification Test after using this product.

De-Energization Test: All associated isolation devices, such as switches, valves etc., should be verified as de-energized prior to and following the use of this CIRLOCK device.

Blocking Verification Test: If this lockout device can not be installed in a manner that will hold the appropriate energy isolating devices in a safe or off position, the device shall NOT be used.

Application: Thread cable end through devices to be locked eg Through a Gate Valve handle and its housing, once or twice as needed; or through Circuit Breakers lockout devices. If a longer cable with a loop is used, now thread end through loop.

Then thread end of cable through lockout device MFL-2, continue till cable is tight, close the lockout device, and place up to 4 padlocks and tags as needed.



Disclaimer: Appropriate use of this product is the sole responsibility of the user in relation to health and safety regulations. Before using, user shall determine the suitability of the product for his intended use and user assumes all risk and liability whatsoever in connection therewith.

Cirlock Pty Ltd is not responsible for any loss or damage arising from the use of this product, which is beyond Cirlock Pty Ltd control, and liability is restricted to the replacement of material proven faulty.

Made by or for:

CIRLOCK

Ph: +61-(0)7-54452910 www.cirlock.com